## AGENCY FOR HEALTH CARE ADMINISTRATION

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X3) DATE SURVEY COMPLETED
	AC13920002	02/19/2018
NAME OF PROVIDER OR SUPPLIER A HIALEAH WOMAN'S CARE CENTER INC	STREET ADDRESS, CITY, STATE, ZIP CODE 952 EAST 25TH ST HIALEAH, FL 33013	

SUMMARY STATEMENT OF DEFICIENCIES
(FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)

## D000 - INITIAL COMMENTS

A State re-licensure survey was conducted on ..., , 2018 at A Hialeah Woman's Care Center Inc. license # 824 had deficiencies found at the time of the visit.

## 0100 - Physical Plant Reg.-2nd Trimester - 59A-9.022, FAC

Based on observation and interview, the facility failed to equip the handwashing stations with mixing valves in each patient procedure . . .

The findings include:

Observation on at 11.40 am, revealed a handwashing sink located inside patients procedure . The handwashing sink did not have mixing valves with hot and water coming from the valves. The handwashing sink ran for a minute and hot water did not come from the valve.

During an interview on at 11:40 am, the Administrator stated that the facility does have a hot water heater but had to cut the line off due to a leaking pipe.

Interview on . . . . . . at 11:55 am, the Administrator acknowledged the facility's handwashing station is not equipped with mixing valves in each patient procedure