

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AC13910039	(X3) DATE SURVEY COMPLETED 12/27/2018
NAME OF PROVIDER OR SUPPLIER ALL WOMEN'S HEALTH CENTER OF NORTH TAMPA,	STREET ADDRESS, CITY, STATE, ZIP CODE 14498 UNIVERSITY COVE PL TAMPA, FL 33613	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
<p>0000 - INITIAL COMMENTS</p> <p>An unannounced relicensure survey was conducted on 12/27/2018 at All Women's Health Center of North Tampa, Inc., an abortion clinic in Tampa, FL.</p> <p>The facility had a deficiency at the time of the visit.</p> <p>License# 814</p> <p>D100 - Physical Plant Req.-2nd Trimester - 59A-9.022, FAC</p> <p>Based on observation and staff interview it was determined the facility failed to ensure supplies were stored safely.</p> <p>Findings included:</p> <p>A tour of the facility was conducted on 12/27/18 at 1:30 p.m. accompanied by the Medical Assistant. The Medical Assistant opened the door to what she referred to as the storage closet. The closet had no shelves. An electrical circuit breaker box was observed on the right hand wall. A telephone junction box was observed on the left wall. A six-foot stepladder was standing against the circuit breaker box. Boxes of various supplies containing plastic and paper were packed into the closet, covering the entire floor wall to wall, to a height of approximately three and a half feet. Seven oxygen e-tanks were observed to be stored at the front- most area just inside the closet door.</p> <p>The Medical Assistant was present at the time of the observations. She confirmed the finding oxygen was stored in proximity to combustible materials. She confirmed the finding the electrical circuit breaker box was not immediately accessible in the event of an electrical emergency.</p>		