

## FIRE SAFETY INSPECTION REPORT

City of Raleigh Fire Department

Office of the Fire Marshal PO Pox 590 Raleigh NC 27602 (919)996-6392 Fax(919)831-6180

A PREFERRED HEALTH CENTER 1604 JONES FRANKLIN RD RALEIGH NC 27606

**Violations Are Indicated Below by Code Reference**

<b>Code</b>	<b>Description</b>	<b>Date Reported</b>	<b>Date Repaired</b>
315.2.3	Combustible material shall not be stored in boiler rooms, mechanical rooms or electrical equipment rooms. HAD A FIRE IN THE H2O HEATER ELEMENT THAT WAS FUELED BY COMBUSTIBLES STORED TOO CLOSE TO SAME.	08-11-2012	03-31-2017

0.56175112724304 seconds