

FIRE SAFETY INSPECTION REPORT

City of Raleigh Fire Department

Office of the Fire Marshal PO Pox 590 Raleigh NC 27602 (919)996-6392 Fax(919)831-6180

A PREFERRED HEALTH CENTER 1604 JONES FRANKLIN RD RALEIGH NC 27606

Violations Are Indicated Below by Code Reference

Code	Description	Date Reported	Date Repaired
315.2.3	Violation carried over from inspection on 08/11/2012 Combustible material shall not be stored in boiler rooms, mechanical rooms or electrical equipment rooms. HAD A FIRE IN THE H2O HEATER ELEMENT THAT WAS FUELED BY COMBUSTIBLES STORED TOO CLOSE TO SAME.	08-11-2012	03-31-2017
0000	Posted building.	02-22-2017	03-31-2017

0.5303270816803 seconds